



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Institute/SZ/2024/ 330

Dated: 30/05/2024

FIRE SAFETY CERTIFICATE

Certified that the **State Council of Educational Research & Training** located at Varun Marg, Defence Colony, New Delhi-110024, comprised of Ground Floor & First Floor [New Block (SPS)] only, owned/occupied by State Council of Educational Research & Training was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/Educational/2021/11 dated 08/01/2021. The said premises was re-inspected by the officer concerned of this department on 22/05/2024 in the presence of Mr. B.B. Karan (Estate Manager) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in according with Director of Education Circular No. F.16/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building/premises is fit for occupancy class "**Educational**" (Group-B) with effect from the date of issuance for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/05/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
01/08

Copy to: -

1. Dr. Mukesh Yadav, Secretary/HOO, State Council of Educational Research & Training, Varun Marg, Defence Colony, New Delhi-110024.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".